



KENAI PENINSULA BOROUGH SCHOOL DISTRICT

Purchasing Department

139 East Park Avenue Soldotna, Alaska 99669-7553

Phone (907) 714-8876

Fax (907) 262-7165

ADDENDUM #1

September 15, 2017

TO: ALL PROSPECTIVE BIDDERS

SUBJECT: INVITATION TO BID - #107-18, Fuel

DUE: **4:00 P.M. Alaska Time, September 29, 2017**

The following changes, additions and clarifications are hereby made to the subject Invitation to Bid:

Prospective bidders question:

You make references to "Heating Fuel," "Fuel Oil #1," "DFA," and "USLD." We would like clarification regarding the specifics of these references since their meanings can overlap.

Change:

Scope of Work, Page 8, All specifications for heating fuel shall be written to include the following:

All heating fuel shall be #1, DFA, whether delivered to an above or below ground tank.

ASTM Specifications – ASTM D975, 1-D (S500) or ASTM D396, Grade 1

NOTE TO PROPOSERS: Please sign and return one (1) copy of this sheet with your Bid to acknowledge receipt of Addendum #1: INVITATION TO BID - #107-18.

BIDDER: _____
(Firm Name)

Mailing Address: _____

Date: _____

Signed by: _____
(Signature and Title)